

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0026:274 Page 1 of 2

**CATEGORY:** Control Units (Non High-Rise)

**LISTEE:** Simplex, 100 Simplex Drive, Westminster, MA 01441-0001  
Contact: Paul Mattern (978) 731-8542 \*Fax (978) 731-8881

**DESIGN:** Model FIREQUEST 200. Local, auxiliary, remote station and central station service; noncoded; automatic, manual, waterflow service and release device service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

900678	Control Board
900683	Expansion Board
900679, 900666	Power Supply
19240463	Relay
19240462	Ammeter
17400031	Voltmeter
900687, 900749	Auxiliary Relay
900810, 900798	Auxiliary Relay
900758	Audible Expansion Board
900770	Expansion Motherboard
900773	Municipal Slave Module
900774	Polarity Reversal Slave
900778	Sprinkler Supervisory Module
900799	Marchtime Coder
900800	4-zone Board
900817	Counting Zone
910245	Bus/Bus Cable
850308	EOL Relay
910262	DD8 Digital Dialer
975692	LCM Addressable Loop
LD-1F	Converter
900688	Halon Control Board
900689	Digital Display Board
900690	Halon Slaveboard
975906	Fiber Optic Modem

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Formerly 7165-0062:123, 7165-1493:130

\*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 13, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager